



12 South Center Street
Bensenville, IL 60106

Office: 630.350.3404
Fax: 630.350.3438
www.bensenville.il.us

VILLAGE BOARD

President
Frank DeSimone

Board of Trustees
Bosa Carmona
Ann Franz
Agnieszka "Annie" Jaworska
McLane Lomax
Nicholas Panicola Jr.
Armando Perez

Village Clerk
Nancy Quinn

Village Manager
Evan K. Summers

December 17, 2018

Mr. Ryan J. Hoff
204 Dearborn Court, Suite 124
Geneva, Illinois 60106

Re: December 13, 2018 FOIA Request

Dear Mr. Hoff:

I am pleased to help you with your December 13, 2018 Freedom of Information Act ("FOIA"). The Village of Bensenville received your request on December 13, 2018. You requested copies of the items indicated below:

"1225-1275 Devon Avenue environmental records."


After a search of Village files, the following information was found responsive to your request:

- 1) Office of the Illinois State Fire Marshal Permit #01312-2015UPG. (1 pg.)

These are all the records found responsive to your request.

Do not hesitate to contact me if you have any questions or concerns in connection with this response.

Very truly yours,


Corey Williamsen
Freedom of Information Officer
Village of Bensenville



Office of the Illinois State Fire Marshal
 Division of Petroleum and Chemical Safety
 1035 Stevenson Drive
 Springfield, IL 62703
 2177851020

FOR OFFICE USE ONLY
 Facility # 2005137
 Permit # 01312-2015UPG
 Request Rec'd 11/23/2015
 Amended Date
 Approval Date 11/24/2015 DS
 Permit Expires 5/24/2016


Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p>(1) OWNER OF TANKS - Corporation, partnership, or other business entity:</p> <p>Murphy 1225 Devon Ave. Bensenville, IL 60106 Contact: Bob Murphy</p>	<p>(2) FACILITY - name and address where tanks are located:</p> <p>Murphy 1225 Devon Ave Bensenville, IL 60106 Contact: Bob Murphy (630) 595-3386</p>
---	---

(3) UPGRADE OR REPAIR OF TANKS:

- (a) Number and size of tanks being upgraded or repaired: (TK # 1, 2, 3) - 12,000, (TK # 4, 5, 6) - 6,000
- (b) Type of tanks:
- (c) Type of piping: (TK # 1, 2, 3, 4, 5, 6) Piping - Other Aboveground Piping, (TK # 1, 2, 3, 4, 5, 6) Piping - Shear Valves, (TK # 1, 2, 3, 4, 5, 6) Piping - Dispenser Sumps containment FRP
- (d) Product to be stored in each tank: (TK # 1, 2, 3, 4) - Gasoline, (TK # 5) - Diesel Fuel, (TK # 6) - Kerosene
- (e) Type of leak detection being used:
 Tank:
 Piping:
- (f) Corrosion Protection being used:
 Tank:
 Piping:
- (g) Spill containment devices, piping, and dispenser containment devices: (TK # 3, 4, 6) Spill Contain Device - Manhole Pre-manufactured EBW 705
- (h) Overfill prevention devices: (TK # 1, 2, 3, 4, 6) Overfill Prev Device - Overfill Drop Tube Valve OPW 61SOP, (TK # 5) Overfill Prev Device - Overfill Drop Tube Valve OPW 71SO-4000 overfill drop tube valve
- (i) Manway accessible at grade:



(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES : Change aboveground gasoline vent piping to comply with OSFM regulations

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

Metro Environmental Contractors, Inc. dba Metro Tank & Pump Company
 1111 West Dundee Road

Contact Person: Larry Cherner
 Phone: (847) 465-4000